



**INSTALLATION NOTE**  
 IF SUBBASE FUEL TANK AND/OR SOUND HOUSING IS USED, REFER TO SUBBASE FUEL TANK DRAWING TO DETERMINE MOUNTING LOCATIONS

MODEL	GENSET WEIGHT (WET)
150 4R13X, 4T13X	1342 KG [2959 LBS]
150 4S12X	1295 KG [2855 LBS]
150 4S13X	1402 KG [3090 LBS]

**NOTES**  
 DIMENSIONS IN [ ] ARE INCH EQUIVALENTS  
 IF AN ENCLOSURE IS USED THE FUEL LINE MUST BE STUBBED UP FROM DIRECTLY UNDER THE UNIT OR BROUGHT IN FROM THE END OF THE SKID. REFER TO ENCLOSURE ADV.  
 ▨ 4 HOLES FOR STANDARD MOUNTING Ø17.5 [0.68]  
 ▴ 10 HOLES FOR IBC MOUNTING Ø17.5 [0.68]  
 IF IBC CERTIFICATION IS REQUIRED SEE SEISMIC ADV FOR INSTALLATION INSTRUCTIONS.

**150 MODEL, 4R13X, 4T13X, 4S12X, 4S13X RECONNECTABLE, IMPROVED MOTOR STARTING (IMS), RECONNECTABLE & 600V ALTERNATOR JOHN DEERE 6068HF**

REV	DATE	ON COMPOSITE DWGS. SEE PART NO. FOR REVISION LEVEL	BY
-	5-20-11	NEW DRAWING [91379-4]	KMP

UNLESS OTHERWISE SPECIFIED:  
 1) DIMENSIONS ARE IN MILLIMETERS  
 2) TOLERANCES ARE:  
 X.XX ± 0.25  
 X.X ± 1.0  
 X ± 1.5  
 ANGLES ± 0° 30'  
 SURFACE FINISH MAX.  
 THIRD ANGLE PROJECTION

APPROVALS	DATE
DRAWN KMP	5-20-11
CHECKED PLD	5-20-11
APPROVED GDF	5-20-11

**KOHLER CO. METRIC PRO-E**  
 POWER SYSTEMS, KOHLER, WI 53044 U.S.A.  
 THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

**TITLE**  
**DIMENSION PRINT, 150 MODEL**

SCALE 0.12 CAD NO. SHEET 1 of 2  
 DWG NO. **ADV-8183**

